



INSPECTION REPORT

Report Issued: Aug 24, 2022

Inspection Result: PARTIAL PASS

Permit Number: SPRRN220511

Issuance Date: Jun 16, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Epic Construction Inc.

Contractor: Epic Construction Inc. 15334 E. Hinsdale Cir., Unit 1D Centennial, CO 80112
(303) 840-8821

To construct: New exterior work to include updated siding, new window and construction of new entry canopies (2). Interior work to include revision to existing floor plan layout and new interior finishes throughout.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Main level exterior walls that had abatement done have been reinsulated with R-15 fiberglass batts with 6 mil poly installed over top. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us