



INSPECTION REPORT

Report Issued: Aug 26, 2022

Inspection Result: PASSED

Permit Number: SPRSG220619

Issuance Date: Jul 18, 2022

Property Address: 225 ANGLERS DR;

Applicant: Powerhouse Retail Services LLC

Contractor:

To construct: Relocating and replace existing illuminated drive thru menu boards with new a few feet from original location.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Footings dug to proper depth with rebar properly sized and spaced. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us