



INSPECTION REPORT

Report Issued: Aug 29, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH210082

Issuance Date: Aug 23, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: Deans Plumbing and Heating Inc

Contractor: Deans Plumbing and Heating Inc 192 East Line Street Bishop , CA 93514

To construct: Installing underground mains,insulation,tubing,manifolds,above ground piping,and pumps to be connected to the flat plate heat exchanger in the mechanical room for the snowmelt system.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: PARTIAL: Ansul Snowmelt mains for Wild Blue lower installed from boiler room to Manifold locations. Tubing test is good at 100psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us