



INSPECTION REPORT

Report Issued: Aug 30, 2022

Inspection Result: PASSED

Permit Number: SPRRN220007

Issuance Date: Feb 03, 2022

Property Address: 345 LINCOLN AVE, UNIT:205;

Applicant: F&C Quezada LLC

Contractor: F&C Quezada LLC 323 Sage Ct Craig, Co 81625 (970) 620-2205

To construct: convert previous forever fit gym into a residential condo

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 5/8 Type X installed on lid and 1/2 Type X installed on walls. All drywall properly fastened. Approved, Ok to tape and finish.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us