



# INSPECTION REPORT

**Report Issued:** Aug 30, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH221109

**Issuance Date:** Aug 08, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Deans Plumbing and Heating Inc

**Contractor:** Deans Plumbing and Heating Inc 192 East Line Street Bishop , CA 93514

**To construct:** Install boilers, overhead and underground snowmelt mains, snow field piping and manifolds

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Snowmelt tubing install over poly iso for area to right of stage to middle of ice rink on east side. Tubing secured the wire mesh Tubing connected to manifold to right of stage and passed test of 100psi. Partial approved.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us