



INSPECTION REPORT

Report Issued: Sep 07, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL220733

Issuance Date: Jun 06, 2022

Property Address:

Applicant: Mechanical & Piping Inc

Contractor: Mechanical & Piping Inc 6440 E. 50th Ave Commerce City, CO 80022 (303) 710-2869

To construct: New Restaurant and Rest room, Wild Blue Gondola Mid Mountain.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: partial underground, sanitary and roof drains approved for what is completed to date, both need to have more work completed on far southwest corner, and west side later today. all sloped properly sitting on compacted gravel and held 5 psi for 15 minutes DWV

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us