



INSPECTION REPORT

Report Issued: Sep 09, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000 Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Basement Level DWV cast iron lines are all approved now for the lower level, inspected two sets of lines with 10 foot of head pressure, and one segment with 6 psi, all held for 15 minutes, all DWV properly sized and supported. The area inspected is to the south of the main interior exit stairs, from the mechanical room below the zamboni room working to the east throughout the storage rooms.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us