



# INSPECTION REPORT

**Report Issued:** Sep 13, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH210774

**Issuance Date:** Dec 16, 2021

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** MTech Mechanical Technologies Group

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** Boiler plant for heating and snowmelt water

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Boiler exhaust duct relocated to permanent location from boiler room to termination. Duct supported vertically and horizontally except in 1 location. Will see final termination and cap plus remaining support at next inspection. Partial approved.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us