



# INSPECTION REPORT

**Report Issued:** Sep 14, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL220977

**Issuance Date:** Jul 18, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Michael KmetzCanyon Plumbing Inc.

**Contractor:** Canyon Plumbing Inc. 29350 Industrial Way #210 Evergreen, CO 80439

**To construct:** furnish and install underground waste pipe, wall rough, plumbing fixtures, floor drains, floor sinks, drinking fountains, water pipe and insulation, water heater, mop sink, recirc pump.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** New gas line installed and properly supported from meter room in Sheraton to Christ sports. Gas line is sized to plans and passed test of 15psi. Schedule Approval for service when Temp heaters hooked up

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us