



# INSPECTION REPORT

**Report Issued:** Sep 20, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL220733

**Issuance Date:** Jun 06, 2022

**Property Address:**

**Applicant:** Mechanical & Piping Inc

**Contractor:** Mechanical & Piping Inc 6440 E. 50th Ave Commerce City, CO 80022 (303) 710-2869

**To construct:** New Restaurant and Rest room, Wild Blue Gondola Mid Mountain.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Above slab DWV and waterlines in Sprung Structure completed to Approved Plans. All waterlines installed, supported and protected with passing pressure test of 100psi. DWV completed to Approved Plans except on west end of building that we be inspected at later time. DWV inspected is supported and protected with passing pressure test of 5psi. Partial Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us