



INSPECTION REPORT

Report Issued: Sep 21, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRAB220362

Issuance Date: Apr 28, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: STEAMBOAT SKI & RESORT CORP

Contractor: STEAMBOAT SKI & RESORT CORP. 2305 MT WERNER CIR STEAMBOAT SPRINGS, CO 80487-9023

To construct: Replace the existing underground Bashor snowmaking valve control building, with a new, confined space compliant building set into the hillside for direct access and egress.

Parcel Number should be 936271001 it would not give that one as a choice.
Tammy

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Walls and wing wall footers, All #5, and all but north wall have 12x12 grid, doubles at the top, extra double above the door. Penetrations and window have 6" grid surrounding. Footers area two continuous.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us