



INSPECTION REPORT

Report Issued: Sep 23, 2022 Inspection Result: PARTIAL PASS

Permit Number: B-21-625 Issuance Date: Jul 22, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: Josh Boh

Contractor: Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112 **To construct:** The Work of Project is defined by the Contract Documents and consists of new

construction and renovation of the Steamboat Base Village.

The work for the Goldwalk project includes a new entry walk, referred to as

the Goldwalk.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See final corrections after walk through inspection today.

Corrections:

- 1 TCO approved:
 - 1. Complete exterior wall on north side, and the pavers that lead you from the exit door to ski time square.
 - 2. Complete the south side exterior wall along the escalator, or at minimum an addendum on how it will be finished per code for exterior finishes.
 - 3. Fire Caulk penetration in electrical room under escalator.
 - 4. Install stairs in ski corp facility tool room that lead up to the concrete floor that leads towards the electrical room and required exit door.
 - 4. Complete all work per the plans, and provide RCRBD with any As-Built conditions that were altered from the original plans under this permit, and provide final copies of all special inspection reports.





Sincerely,

Todd Carr Building Official tcarr@co.routt.co.us