



INSPECTION REPORT

Report Issued: Sep 26, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000 Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Hot and cold water lines installed in area between grid lines A-C.1 and grid lines 4-8 and to Zamboni room. All pipes supported and protected. Water lines test is good 100psi.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us