



# INSPECTION REPORT

**Report Issued:** Sep 26, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH221078

**Issuance Date:** Aug 03, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Griff Osman

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** New Mechanical for SPRNR220115

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Steel and copper heating water and chilled water pipes installed to Approved Plans on Lower level of Promenade. All pipes are properly supported and passed test on three gauges at 100psi. Partial Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us