



# INSPECTION REPORT

**Report Issued:** Sep 27, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** B-21-625

**Issuance Date:** Jul 22, 2021

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Josh Boh

**Contractor:** Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112

**To construct:** The Work of Project is defined by the Contract Documents and consists of new construction and renovation of the Steamboat Base Village.  
The work for the Goldwalk project includes a new entry walk, referred to as the Goldwalk.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: 2nd half of shaft for boiler flue installed and shaft liner completed to approved assembly. 1st layer 5/8 Type X drywall installed on outside of shaft on third level.  
Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us