



INSPECTION REPORT

Report Issued: Sep 28, 2022

Inspection Result: PARTIAL PASS

Permit Number: SPRMH210082

Issuance Date: Aug 23, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: Deans Plumbing and Heating Inc

Contractor: Deans Plumbing and Heating Inc 192 East Line Street Bishop , CA 93514

To construct: Installing underground mains,insulation,tubing,manifolds,above ground piping,and pumps to be connected to the flat plate heat exchanger in the mechanical room for the snowmelt system.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Snowmelt tubing installed in stairs on lower plaza. Tubing properly secured to wire mesh of R-6 insulation and vapor retarder. Tubing run to manifold location.and passed test of 100psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us