



# INSPECTION REPORT

**Report Issued:** Sep 29, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRRN220511

**Issuance Date:** Jun 16, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Epic Construction Inc.

**Contractor:** Epic Construction Inc. 15334 E. Hinsdale Cir., Unit 1D Centennial, CO 80112  
(303) 840-8821

**To construct:** New exterior work to include updated siding, new window and construction of new entry canopies (2). Interior work to include revision to existing floor plan layout and new interior finishes throughout.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: 7-8 inches of closed cell foam installed in new roof on third floor. R-19 fiberglass batts installed in exterior walls on southwest walls. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us