



# INSPECTION REPORT

**Report Issued:** Sep 29, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL221410

**Issuance Date:** Sep 27, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Griff Osman

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** Waste/Vent, Bathroom

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: DWV and waterlines for bathroom in Logo Shop completed to Approved Plans. All pipes properly supported and passed tests. DWV test is good at 5psi and waterlines good at 100psi. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us