



INSPECTION REPORT

Report Issued: Sep 29, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: B-21-625

Issuance Date: Jul 22, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: Josh Boh

Contractor: Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112

To construct: The Work of Project is defined by the Contract Documents and consists of new construction and renovation of the Steamboat Base Village.
The work for the Goldwalk project includes a new entry walk, referred to as the Goldwalk.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Exterior grade fire rated plywood installed on exterior walls of Logo Shop and properly fastened, Ok to cover walls in drywall. 1st layer of 5/8 Type X drywall installed on exterior side of shaft per assembly on 1st and 2nd floor. and second layer installed on 3rd floor. All drywall is properly fastened. Layer of 5/8 of 5/8 Type X installed on lid to cover all patches.
Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us