



INSPECTION REPORT

Report Issued: Sep 29, 2022

Inspection Result: **FAILED**

Permit Number: SPRAB210782

Issuance Date: Feb 03, 2022

Property Address: 2643 COPPER RIDGE CIR;

Applicant: Erik Lobeck

Contractor:

To construct: 2 10x20 STORAGE CONTAINERS ON A COPPER RIDGE INDUSTRIAL PARK
PARCEL

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: No level gravel pad has been constructed for shipping containers, they are sitting on shimmed timbers on a slope. Construct level gravel pad or change foundation system.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us