



INSPECTION REPORT

Report Issued: Oct 03, 2022

Inspection Result: PASSED

Permit Number: SPRMH221444

Issuance Date: Sep 29, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: All Purpose Mechanical

Contractor: Epic Construction Inc. 15334 E. Hinsdale Cir., Unit 1D Centennial, CO 80112
(303) 840-8821

To construct: HVAC System and Temp Heat

On this day we have inspected your construction for **Approval for Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: approval for gas meter to be installed on 2" line feeding Christy sports from Sheraton gas meter room to Christy sports. Contractor to install fire caulk as the 2" line penetrates all cmu walls, three total walls penetrated.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us