



INSPECTION REPORT

Report Issued: Oct 12, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221078

Issuance Date: Aug 03, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Griff Osman

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New Mechanical for SPRNR220115

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Lower level HVAC in promenade building installed to Approved Plans between grids A and F except changes to UC Health space. Flex connection in space 123 and in Mechanical Ice Plant. need to be installed. All dampers installed and ready for flex to grilles in grid ceiling Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us