



INSPECTION REPORT

Report Issued: Oct 18, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH210774

Issuance Date: Dec 16, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: boiler plan and snow melt

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Contractor applied air to the lines in the lower level of the promenade at 100 psi for 15 minutes over the weekend, then tied into all hydronic tubing in the promenade square upper level to turn on the boiler in advance of cold weather. Connection was with press fittings just on the interior side of the foundation wall in northwest corner.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us