



INSPECTION REPORT

Report Issued: Oct 20, 2022	Inspection Result:	PARTIAL PASS
-----------------------------	--------------------	--------------

Permit Number: SPRPL210563
Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co

80234 (719) 782-4000Holly Klein 12300 Pecos Street Wesminster, CO 80234

(303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Approval for Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: temp heat approved for approval of service, all gas lines including flex line to temp heater approved held 16 psi for 15 minutes, contractor must connect exhaust line yet

Corrections: Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us