

PJ1892-2
Fire Prevention
In: 5/27/2016
Out: 06/01/2016

RCRBD
RECORD
SET

EDGEMONT CONDO'S
2410 SKI TRAIL LANE
STEAMBOAT SPRINGS, CO.

- FLUE CHIMNEY REPAIRS
FROM FIRE DAMAGE
EOD - W/ 01/20/16

PROVIDE 1" TYPE "X"
OVER INFILL SECTION
EXTEND 3" PAST
JOINT & FIRE TAPE END

INFILL OUT OUT SECTION
W/ 1" TYPE "X"
GYPSUM PANEL
FIRE TAPE JOINT.

ELEVATION

SHAFT WALLS			
GA FILE NO. WP 7051	PROPRIETARY*	2 HOUR FIRE	50 to 54 STC SOUND
GYPSUM WALLBOARD, STEEL C-H OR C-T STUDS			
One layer 1" x 24" proprietary type X gypsum panels inserted between 2 1/2" floor and ceiling J runners with T section of 2 1/2" steel C-H or C-T studs between panels.			
OPPOSITE SIDE: Base layer 1/2" proprietary type X gypsum wallboard applied at right angles to studs with 1" Type S drywall screws 24" o.c. Face layer 1/2" proprietary type X gypsum wallboard applied parallel to studs with 1 1/2" Type S drywall screws 12" o.c.			
Sound tested with 1 1/2" glass fiber insulation in stud space. (NLB)			
PROPRIETARY GYPSUM BOARD			
American Gypsum Company LLC	-	1/2" FireBloc® Type C	Thickness: 3/4"
CertainTeed Gypsum Inc.	-	1" Shaft Liner	Approx. Weight: 8 pcf
National Gypsum Company	-	1/2" ProRoc® Type C Gypsum Panels	Fire Test: UL R7094, 93NK8151, 9-14-93, UL F3660, 07NK22992, 2-18-08, UL Design L429
PABCO Gypsum	-	1" GlasRoc® Shaftliner Gypsum Panels	Sound Test: RAL TL53-181, 7-1-93
Temple-Inland	-	1/2" Gold Bond® Brand FIRE-SHIELD™ Gypsum Board	
	-	1" Gold Bond® Brand FIRE-SHIELD® Shaftliner	
	-	1/2" FLAME CURB® Super C™	
	-	1" PABCORE® Gypsum Liner Board	
	-	1/2" TO-C	
	-	1" Silent Guard™ Gypsum Liner Board	

1" TYPE "X" INFILL PANEL
1" OVER-LAY

PROVIDE 2-5/8" TYPE "X" GYP. LAYERS LAPPED
3". FIRE TAPE EA. LAYER.

SHAFT WALL PATCH REPAIR

2 HR RATING
SIM. TO GA #WP 7051

3" = 1'-0"