



## Corrections Notice

October 24, 2023

Permit Application: SPRSW231375

Property address:

Following are the comments regarding the plan review for the above referenced application. We have noted several concerns and/or non-conforming items regarding the work to be performed. These items must be addressed through revised drawings submitted online through your My Items page in order to proceed.

**Construction Stormwater Review** (Reviewed By: Scott Slamal )

1. 1. Update City Construction Stormwater Permit form to accurately reflect responsible individuals including the qualified stormwater manager. Sign permit and upload to cityview.
2. Sheet C17 (Site Plan) as referenced in the SWMP, is not included with the submitted documents.
3. Describe proposed control measures used for Land disturbance and storage of soils.
3. Describe proposed type of VTC.
4. Describe control measures for loading and unloading.
5. Describe control measures for material storage and stockpiles.
6. On-site waste management practices must include more than one dumpster.
7. Due to the likely hood of encountering groundwater, a de-watering plan is required as part of this SWMP.
8. Include control measure specification sheets for all proposed control measures.

If I can provide any further information to you, please feel free to contact me at (970) 871-8236 or by email at [sslamal@steamboatsprings.net](mailto:sslamal@steamboatsprings.net).

Sincerely,

A handwritten signature in black ink, appearing to read 'SSlamal', with a stylized flourish at the end.

Scott Slamal

Stormwater Inspector