



Corrections Notice

November 07, 2023

Permit Application: SPRSW231375

Property address:

Following are the comments regarding the plan review for the above referenced application. We have noted several concerns and/or non-conforming items regarding the work to be performed. These items must be addressed through revised drawings submitted online through your My Items page in order to proceed.

Construction Stormwater Review (Reviewed By: Scott Slamal)

1. 1. Update City Construction Stormwater Permit form to accurately reflect responsible individuals including the qualified stormwater manager. Sign permit and upload to cityview.
2. Describe control measures for dust control.
3. Further describe tracking control measures.
4. On-site waste management practices must include more than one dumpster. Define "good housekeeping practices."
5. Due to the likely hood of encountering groundwater, a de-watering plan is required as part of this SWMP.
6. Include control measure specification sheets from MHFD for all proposed control measures.

If I can provide any further information to you, please feel free to contact me at (970) 871-8236 or by email at sslamal@steamboatsprings.net.

Sincerely,

A handwritten signature in blue ink, appearing to read 'SSlamal', is written over a horizontal line.

Scott Slamal

Stormwater Inspector