

Ted Allen

From: Ted Allen
Sent: Monday, December 19, 2016 1:27 PM
To: 'jake@seadinc.com'
Cc: Malea Michael-Ferrier; Amber Gregory
Subject: Permit/Application: TB-16-453 at 135 11TH ST, STEAMBOAT SPRINGS for Alterations- Steamboat

Jake,

The above referenced application appears satisfactory with the following exceptions:

A change in kitchen equipment under an existing hood, such as the installation of a gas range in a commercial kitchen, requires a Type I hood and different levels of exhaust.

Verify existing conditions and re-submit plans if required by such changes, designed under the appropriate provisions of the adopted codes including requirements for the production of grease.

Include similar documentation with Steamboat utilities for similar requirements for grease interceptor, if applicable.

Thanks,

Ted Allen, P.E., C.B.C.O. Assistant Building Official
Routt Co. Regional Bldg. Dept.
136 Sixth Street/P.O. Box 773840 Steamboat Springs, CO 80477
(970) 870-5329

tallen@co.routt.co.us



Please consider the environment before printing this email.