



DESIGN 2 FUNCTION, LLC

P. O. Box 93368, Albuquerque, N.M. 87199-3368

Info@design2functionllc.com * (505) 823-6481

Architect's Supplemental Instructions









A.S.I. #: 3
Project: Holiday Inn Express & Suites, Steamboat Springs, Colorado
General Contractor: Maurer Construction
Date of Issuance: 6/12/24

The work shall be carried out in accordance with the supplemental information noted below. If there is any change to the Contract Price or Contract Time, the Contractor shall inform the Architect and Owner within 10 days.

Description:

- a. Clarified pool deck drainage intent by noting sump pit and pump (by pool contractor), changing floor drain to a floor sink for indirect drainage of sump pump and for filter back wash.
- b. Added circuit for sump pump to electrical drawings (plan and panel schedule).

Revised Drawings (4):

Name	Status	Date modified
 95 HIESCO-P1.1-revised-6-11-24		6/12/2024 10:38 AM
 96 HIESCO-P2.0-revised-6-11-24		6/12/2024 10:38 AM
 123 HIESCO-E3.0-revised-6-11-24		6/12/2024 11:04 AM
 133 HIESCO-E6.2-revised-6-11-24		6/12/2024 11:04 AM

Design 2 Function, LLC



Nick A. Pirkl
Principal