

NORTHWEST COLORADO CONSULTANTS, INC.
FIELD REPORT

Project: Torian Plum Parking Structure	Project No.: 18-11098	Date: 6/4/18
Location: Steamboat Springs, CO	Report No.: 1-HP	Time: 3.5
Client: Martin & Martin		Mileage: 10
		Engr. /Tech: CR

Work Performed:

As requested, we visited the project site on today's date to observe the screw pile installation operations. The pile contractor, Inc 8, installed (3) pier-tech 5150 double helix screw piles for the pool equipment boiler room expansion.

A summary table of the piles completed on this date is attached

Remarks:

Based on our observations and measurements, the piles completed on this date appeared to be installed to refusal conditions in natural gravels.

Verbal Discussions:

Ken Fones of Duckels Construction was aware of today's observations and measurements.

HELICAL SCREW PILE OBSERVATION DATA SHEET

Date: 6/4/18

[illegible]

Notes: