


522 Shield Dr
Steamboat Springs, CO

2740 Acre Lane, Suite E
Steamboat Springs, CO



2 — SIN
NTS

1. ALL WORK SHOWN IS NEW, UNLESS NOTED OTHERWISE.
2. ALL WORK TO BE IN ACCORDANCE WITH NATIONAL ELECTRIC CODE, 2020 EDITION.
3. SEAL ALL CONDUIT PENETRATIONS OF FLOORS AND FIRE RATED ASSEMBLIES TO MAINTAIN FIRE RATING.
4. PROVIDE NEW TYPEWRITTEN DIRECTORIES REFLECTING WORK PERFORMED FOR ALL NEW PANELBOARDS IN THIS PROJECT.
5. PLANS ARE PREPARED WITH REQUIRED BRANCH CIRCUITS INDICATED BY CIRCUIT NUMBERS. PROVIDE AND INSTALL ALL CONDUITS, CONDUCTORS, BOXES, MISCELLANEOUS FITTINGS, ETC. FOR A COMPLETE AND OPERABLE SYSTEM (HOMERUN SHOWN). BRANCH CIRCUIT INSTALLATION SHALL COMPLY WITH SPECIFICATIONS AND N.E.C.
6. ALL NEUTRAL CONDUCTORS ON POWER BRANCH CIRCUITING ROUNDHOUSES TO BE #10 AWG UNLESS NOTED OTHERWISE.

A circular professional engineer seal for the state of Colorado. The outer ring contains the text "COLORADO LICENSED" at the top and "PROFESSIONAL ENGINEER" at the bottom. Inside the ring, the name "ANDREW CHARLES WILDER" is written in a semi-circle at the top, and the license number "49009" is in the center. A blue ink signature is scrawled across the bottom half of the seal.

Scale:	NTS
24x36	
Description:	ONE LINE, LOAD CALC
Project Name:	RIVERFRONT - BLDG 3, UNIT 2
Project Number:	2024003

E-1.1