



ROUTT COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

Todd Raper
NEI Construction
629 Sawatch Road
Eagle, CO 81631

Re: Edgemont 'Future' Spa

May 31, 2018

Dear Todd,

I have finished reviewing the plans and specifications for the additional spa at Edgemont in Steamboat Springs, CO. Under the provisions of the State of Colorado Swimming Pool and Mineral Bath Regulations, the **Routt County Department of Environmental Health** approves your project. Please contact me if plans change at any time prior to final installation.


Please be cognizant of the following details:

1. All public pools and spas must comply with the standards set forth by the Virginia Graeme Baker Safety Act.
2. According to Section 4.9, it is required to have a Certified Pool Operator, an Aquatic Facility Operator, or a National Spa and Pool Institute Technician on staff or under contract to maintain a record of information regarding operations of the pool and spas at Edgemont.

Levels of pH, disinfectant concentration (Chlorine), total alkalinity, calcium hardness, flow, and water temperature should be included in this record. Water-testing equipment must be provided to monitor these items.
3. Section 3.1 – Depth markers shall be a minimum of four-inch numerals in a contrasting color on the deck and four-inch numerals in a contrasting color on the vertical wall of the new spa at or above water level.
4. Section 3.17 – An emergency shutdown station shall be provided at a place that is convenient, yet secured from the public. This station shall have capability to halt water circulation, mechanical, chemical feed and electrical devices. The emergency shutdown shall be accessible to a standing adult.
5. Section 4.11 - Signage shall be provided to address bather loads and the absence of an on-duty lifeguard.

Upon completion of installation, I will perform a final inspection of the new spa to assure compliance with the Regulations. Please call me at (970) 870-5588 in advance to schedule this appointment. Thanks for your cooperation and good luck!

Sincerely,

A handwritten signature in cursive script, reading "H Savalox".

Heather Savalox, MPA, REHS
Senior Environmental Health Specialist

cc: Routt County Building Department

B-18-318