



## Corrections Notice

December 03, 2024

Permit Application: SPRSG241816

Property address: 1847 SKI TIME SQUARE DR, UNIT:C-2C;

Corey,

The initial review is complete for the sign permit SPRSG241816. Please review the following correction regarding the plan review for the above referenced sign application. These items must be addressed through revised drawings submitted online through your CityView Portal My Items page in order to proceed within the next 30 days or by 1/2/25.

**Planning Review Corrections:** (Reviewed By: Darby Kenyon )

1. The projecting sign does not meet the minimum elevation standard. In sidewalks and other pedestrian circulation areas, the minimum sign clearance shall be eight feet, Sign Code Section 508.F.

If I can provide any further information to you, please feel free to contact me at (970) 871-8259 or by email at [dkenyon@steamboatsprings.net](mailto:dkenyon@steamboatsprings.net).

Sincerely,

A handwritten signature in cursive script that reads "Darby Kenyon".

Darby Kenyon

Planning Technician