



November 21, 2024

Mr. Dan MacEntee

Reference: Steamboat Duplex  
200 Sundance Court  
Steamboat Springs, CO 80487  
Permit Number: SPRSF241394-BD1

Dear Mr. MacEntee,

Per the request of the contractor, I Jacob Mielke, P.E. of Steamboat Engineering And Design, Inc, (SEAD) visited the site on November 20, 2024 to inspect three locations where large existing boulders interrupt the proposed footings. Based on my observations, it is acceptable to leave the boulders in place and pour the footings around them.

This report is based on the site observations made on November 20, 2024. SEAD reserves the right to amend the statements above if any additional information is discovered. If the contractor finds any discrepancies in the field, SEAD must be notified immediately to perform a field inspection and determine the appropriate steps forward. This report does not guarantee the work of the contractor, nor does it relieve the contractor from performing their work in accordance with the contract documents and applicable codes, laws, rules, and regulations. Please contact me if you have any questions regarding this letter. Thank you for inviting SEAD to be part of your project.

Sincerely,

Steamboat Engineering And Design, Inc.  
Jacob Mielke, P.E., President SEAD Inc.  
Colorado License 52418

**REVIEWED  
FOR CODE  
COMPLIANCE**  
  
**12/04/2024**

