



Corrections Notice

February 10, 2025

Permit Application: SPRMU230307

Property address: 1901 CURVE PLZ;

Following are the comments regarding the plan review for the above referenced application. We have noted several concerns and/or non-conforming items regarding the work to be performed. These items must be addressed through revised drawings submitted online through your My Items page in order to proceed.

REF: 1.30.25 Addendum

Utilities Review - City (Reviewed By: Amber Gregory)

1. update landscape plan to provide mi 5' separation from the service and irrigation box. Also provide square footage of irrigated area.

If I can provide any further information to you, please feel free to contact me at (970) 870-5334 or by email at mmichael-ferrier@co.routt.co.us.

Sincerely,

A handwritten signature in black ink that reads 'Malea Michael-Ferrier'.

Malea Michael-Ferrier

Sr Permit Tech/Plan Reviewer Assistant