

April 14, 2025

Plan Review Response  
SPRSF250158 and SPRSF250159  
Permit Review Corrections Notice, dated April 10, 2025

Below is a list of corrections or comments, with associated response for each:

**Utilities Review – Mt. Werner (Beau Cahill)**

1. Reference document mark ups with permit SPRSF250158 (unit a), for revisions needed to utility plan. 4/10/25  
Update: Referencing the duplex service detail on the site and utility plans is not sufficient. You must include and show three curb stops, one on each service line and one on the primary water stub coming off the main.  
**Sheet A1.1 has been updated to show the additional curb stop and connecting lines.**