

FireGuard E-84 1920 Bridge Lane Unit 13

The spread rate for FireGuard-84 states on the directions that one gallon will cover 87 Sq. Ft. at a thickness on 10 mils. So 2.5 gallons will cover 87 Sq. Ft. at a thickness of 25 mils. The garage ceiling is 360 Sq. Ft. This will require 11 gallons to achieve a thickness of 25 mils in the garage. 11 gallons were sprayed on August 7th and 8th at a rate of 3 coats per day for a total of 6 coats sprayed.

The living area ceiling is 440 Sq. Ft. This will require 12.5 gallons to achieve a thickness of 25 mils. 12.5 gallons were sprayed on August 14th and 15th at a rate of 3 coats per day for a total of 6 coats sprayed.

The bathroom ceiling was sprayed with 3 coats on August 14th and 3 coats on August 15th to achieve a 25 mil thickness.

The hall wall was sprayed with 3 coats on August 14th to achieve a thickness of 10 mils.

1.5 gallons were sprayed between the bathroom and hall.

A total of 25 gallons were sprayed for all locations.

Jerry Stanford

Colorado Joint Ventures Construction

jstanfordcjv@gmail.com

970-846-2992