From: Jason Partovi
To: Todd Carr
Subject: Hypnotic Chicken Walk in Cooler
Date: Friday, December 4, 2020 8:45:58 AM
Attachments: image001.png

Hi Todd,

The walk in cooler as discussed was included in our lease and I believe was used by a previous tenant (Moon Hill Dairy?). We relocated the unit, moved the compressor to the roof and installed a solid self-closing door that meets DOE requirements. I have also attached a picture with the modified condenser enclosure.

1. Door fully closes on its own
2. The door has spring hinges to self-close
3. The walls and ceilings are typical walk in cooler panels that are 4" thick and filled with EPS foam.
4. N/A
5. N/A
6. N/A
7. Evaporator fan is made by Larkin. It has two 1/15 HP motors. I will try to get energy usage information on this.
8. Condensing unit has a 1.5 HP Copeland Compressor
9. N/A
10. N/A
11. Uses LED Lighting. ~60 Lumens per Watt

Regards,

Jason

From: Todd Carr <tcarr@co.routt.co.us>
Sent: Wednesday, December 2, 2020 4:15 PM
To: jason@hypnoticchicken.com
Subject: MD Appliance

Jason,

Mark got a permit for compressor unit, it M-20-750 and it's been issued, so were good on the item and will do a final inspection once the screen is installed over the open side of the unit on the roof.

B-20-139
Next, Walk-n-Coolers fall under the Energy Code, and I have provided some code sections above for you to review, I highlighted the applicable section in yellow for you. If you can provide me some information on these items so I can understand the As-built condition of the cooler in regards to the code sections that would be helpful. Some of these items if they are not met, can be done still as you read through them, other sections if you don't meet the requirements let me know and we can work

through these items if needed with code modification requests on insulation values in floors, walls, ceilings. If you can provide me as much information per item as possible that would be great.

Thanks Jason,
Todd Carr

Todd Carr, Building Official

Routt County Regional Building Dept.
136 6th Street, Suite #201
Steamboat Springs, CO 80487
O: 970-870-5330
C: 970-846-4954
tcarr@co.routt.co.us

Need local information about COVID-19 (coronavirus) in Routt County?
Email for COVID-19 related questions: CountyInfo@co.routt.co.us
Routt County COVID-19 website: www.covid19routtcounty.com

Disclaimer

The information contained in this communication is confidential and intended solely for use by the recipient(s). If you are not the recipient, understand that any disclosure or distribution of the contents is strictly prohibited and may be unlawful. This email has been scanned for viruses and malware, and may have been automatically archived.