



Dan LeBlanc
PO Box 772073
Steamboat Springs, CO 80477
CObuildingperformance@gmail.com
970-439-8606

January 13, 2026

Dan MacEntee

Project: 200 Sundance Ct - Blower Door Test Results

The home was tested for air-leakage rates relative to the 2021 IECC requirement of 3 air-changes per hour (ACH) at the standard rate of 50 Pascals negative pressure. The test was conducted with a blower door, infrared camera and chemical smoke. The project is nearly complete.

Permit number	SPRPF241394
Square footage (sf)	4100
Avg Ceiling ht.	11.0
Volume (cu ft)	45100
Maximum leakage @ ACH50 = 3 x Volume	135300
Maximum Air-leakage (cfm)	2255
Measured leakage @50 Pa (cfm)	1263
Measured leakage (cf/hour)	75780
Divide by Volume = Measured ACH50	1.68
Result	Pass





Dan LeBlanc
PO Box 772073
Steamboat Springs, CO 80477
CObuildingperformance@gmail.com
970-439-8606

Colorado Building Performance

Dan LeBlanc is a recognized leader in energy efficiency and sustainability. He has 20+ years of experience in building energy performance including building envelope optimization, energy modeling, auditing, commissioning and energy management. He has worked on a wide range of project types nationally and internationally including institutional, multi-family, office, manufacturing, core and shell, master plan, and mixed-use. As a LEED professional, he has successfully delivered more than 50 certified projects. Dan is also well versed in the construction process, having managed successful residential and institutional projects as a General Contractor.

Dan LeBlanc has been a BPI certified Building Analyst Professional for 8 years.

BPI ID #5056364, original certification in 2015, re-certified 12/11/2024.

