



Re-Roofing Permit is approved, however the same Class of Roofing materials must be installed to match that of the existing materials to be removed, no new roof assemblies allowed that may create concealed spaces, or build up of existing roof deck without a full review from Building. This is a like for like replacement approved.

Permit Application for Torian Plum Tear off and re-roof.

Address – 1855 Ski Time Square

Dumpster Location is in Red. It is the parking spaces of Torian on the west side of the building. This location has been ok'd by the Torian Plum management team.

The roof is made up of 2 material sections:

- A. Rubber EPDM - This 55 squares of materials.
- B. Composite GAF shingles – This section is 220 squares

If there is any more information needed please use this email or my cell is 846-7711.

Thank You,
Shawn Sullivan
Tin Man Roofing

This occupancy has a monitored fire alarm system. Please take precautionary measures prior to work to avoid nuisance alarm activation. Info 879-7170. Please maintain emergency access during construction work. Any fire alarm / sprinkler work or alterations require a permit to be submitted to Fire Prevention. See www.steamboatsprings.net, Fire and EMS Services, Fire Prevention, Downloadable Permits and Forms.

PJ4287-1
Fire Prevention
In: 07/28/2020
Out: 07/28/2020