

NORTHWEST COLORADO CONSULTANTS, INC.
FIELD REPORT

Project: SBGBTR	Project No.: 21-12047	Date: 6/22/21
Location: SBS, CO	Report No.: 3-SP	Time: 1.0
Client: Steamboat Ski Corp.		Mileage: 6
		Engr. /Tech: MN

Work Performed:

As requested, we visited the project site on today's date to provide special inspections of the reinforcing steel placed for the gondola terminal elevator pit base walls to just above ground level.

Remarks:

Based on our visual observations, the reinforcing steel noted above appeared to have been placed in general accordance with the Structural Drawings, Details, 8 on Sheet 5.501.

It should be noted that today's observations are made with respect to the rebar placement only and do not constitute a complete special inspection of the structure. Elements such as layout, size, elevations, or other architectural aspects are not considered in our observations.

Verbal Discussions:

Jose Gutierrez of Sierra Concrete Company was notified of today's observations.