



136 6th Street, Suite 201
Steamboat Springs, CO 80487
(970) 870-5588
E-Health@co.routt.co.us

Ted Serafy
2305 Mt. Werner Circle
Steamboat Springs, Co 80487

Re: Last Tracks

June 8, 2021

Dear Ted,

I have finished reviewing the plans and specifications submitted for the Last Tracks located at 1847 Ski Time Square in Steamboat Springs, Colorado. Based upon this information the Routt County Department of Environmental Health approves your project.

Please be cognizant of the following criteria, which can sometimes be overlooked during construction of a new retail food establishment. Three-compartment sinks, food-preparation sinks, condensate lines, and ice machines must all drain indirectly to floor drains or floor sinks. Only hand sinks may be directly drained. All kitchen surfaces must be smooth, non-absorbent, and easily cleanable. All outer openings must be secure from the entrance of pests.

Contact me a few days in advance at (970) 870-5588 to schedule your opening inspection.
Thanks for your cooperation and good luck!

Sincerely,

A handwritten signature in black ink, appearing to read 'Rick Melzer'.

Rick Melzer
Environmental Health Specialist