



Corrections Notice

August 30, 2022

Permit Application: SPRROW221188

Property address: 1901 CURVE PLZ;

Following are the comments regarding the plan review for the above referenced application. We have noted several concerns and/or non-conforming items regarding the work to be performed. These items must be addressed through revised drawings submitted online through your My Items page in order to proceed.

ROW Permit Review - Engineering (Reviewed By: Emrick Soltis, P.E.)

1. Only half of the road is allowed to be closed for this work. Revised TCP and resubmit. Also include the dates for this work specifically.

If I can provide any further information to you, please feel free to contact me at (970) 879-1807 or by email at dvanwinkle@steamboatsprings.net.

Sincerely,

David Van Winkle

Streets Superintendent