

Submittal Requirement Waiver: Waivers must be approved by the respective reviewing agency and the approved waiver must be submitted with the application to be considered complete. If the waiver is not approved, the report is required for a complete submittal.

Project Information

Project Name MWW Village Dr Booster Station
 Physical Address MWW Booster Station (no address) located in NW quarter PIN 137177001
 Legal Description BLDG D & F, THE LODGE AT STEAMBOAT, BUILDING COMMON
 Parcel ID # 137177001 AREA, FILE NO. 8825

To waive any of the following items, contact the Community Development Engineer at 970-871-8227 or sking@steamboatsprings.net

Traffic Impact Analysis Report

Reason for Waiver No new users or traffic associated with the project.
 Approved? Y N Determined By _____ Date _____

Soils & Geo-Technical Report

Reason for Waiver No significant grading. Proposed skid mounted pumphouse on stem wall foundation. Open hole inspection to be performed during construction.
 Approved? Y N Determined By _____ Date _____

Drainage Study

Reason for Waiver Reduce impervious area by replacing existing 33'x19.5' permanent structure with 42'x13' skid mounted pump shack w/ modular booster pump station, reducing impervious area by 29% from 643.5 SF to 546 SF.
 Approved? Y N Determined By _____ Date _____

To waive the report below, contact City of Steamboat Springs Water District Utilities Engineer at 970-871-8211 or agregory@steamboatsprings.net

Water Demand Report

Reason for Waiver No new fixtures associated with project.
 Approved? Y N Determined By _____ Date _____